



Control Components Pty Ltd
 ABN 24 080 175 293

PO Box 212
 Caringbah NSW 1495
 Sydney Australia
 ph: +61 (0)2 9542 8977
 fx: +61 (0)2 9542 7978
 www.controlcomponents.com.au
 HELP@controlcomponents.com.au

Trimod Besta level switch approvals by Standards Australia

FLAMEPROOF - Switch housing. SA certificate: AUS Ex 1165, Switch modules: X*9	Ex de IIC T6 IP66/67 Class I Zone 1 i.e. XAA90104, XAA901140
FLAMEPROOF - Hermetically Sealed switches. SA certificate: AUS Ex 1118X SA certificate: AUS Ex 1172X Switch modules: Z*9 & N*9	Ex ed IIC T* IP66/67 Class I Zone 1 Ex nd IIC T* IP66/67 Class I Zone 2 i.e. ZKK90104, ZKK901140
DUST IGNITION PROOF SA certificate: AUS Ex 1181X Switch modules: D*9	DIP T* IP66/67 Class II i.e. DAA90104, DAA901140
INTRINSIC SAFETY SA certificate: AUS Ex 1068X, Switch modules: B*9 & I*9	Ex ia IIC T* IP65 Class I Zone 0 i.e. BB90104, BB901140
PNEUMATIC No SA testing required Switch modules: MV & PV	i.e. MV0104, PV0104

Refer page 10 of the Trimod Besta short form catalogue LTFA4E or pages 22 - 25 of Trimod Besta full catalogue LTKAE1, for further details.

Certificate photocopies available on request.

Control Components Pty Ltd